

Duquesne Light Company

Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077-0004

JOHN D. SIEBER
Vice President - Nuclear Group

1412/ 393.5256

July 25, 1991


U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Operating License Change Request No. 176 Revision 1
Modification (TAC No. 76889)

The purpose of this letter is to provide a modification to Operating License Change Request No. 176, dated April 19, 1991. That request proposed a change to the overpressure protection system (OPPS) setpoint from 350 psig to 444 psig. Attached is a modification to reduce the OPPS setpoint by 4 psig to 440 psig based on the results of WCAP-12966 (Duquesne Light Company, Beaver Valley Power Station Units 1 & 2, 20 Percent Steam Generator Tube Plugging Analysis Program, Engineering and Licensing Report). This modification has been discussed with our NRC Project Manager and is provided to document the change to the proposed Technical Specification amendment.

The previously submitted Attachment B (Safety Analysis and No Significant Hazard Evaluation) remains applicable for this modification. This submittal provides a more conservative setpoint in accordance with WCAP-12966 which was reviewed and approved by the Onsite Safety Committee (OSC), and Offsite Review Committee (ORC).

Sincerely,


J. D. Sieber
Vice President
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. A. W. DeAgazio, Project Manager
Mr. M. L. Bowling (VEPCO)

9107310001 910725
PDR A/LOCK 05000334
PDR

A001
11