

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)01 CAS 05 32 00-000000-0003 411114 5
7 8 9 12 15 25 26 30 37 CAT 38

CONT

01 REPORT SOURCE L6 050003627 0401838 08088839
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 5, the early warning fire detector in Zone 6 was found inoperable

03 during performance of the 6-month fire detection channel functional test. An

04 hourly firewatch was posted within one hour in accordance with LCO 3.3.3.7 Action

05 Statement 'a'. Health and safety of the public were not affected.

06

07

08

09
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
A B 11 E 12 X 13 I N S T R U 14 E 15 Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LER/RO REPORT NUMBER 83 21 22

23 24 26 27 28 29 30 31 32

18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

33 34 35 36 37 38 39 40 41 42 43 44 45

46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The inoperability of the Zone 6 fire detector was due to a melted element in the

11 fusible heat detector. The cause of the melted element cannot be determined.

12 The detector was replaced and was tested satisfactorily on May 31, 1983. This

13 event is considered to be an isolated occurrence and no further corrective

14 action is planned.

15
FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
B 28 000 29 NA B 31 Surveillance Testing
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 3216
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 NA NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 3217
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39) NA
0 0 0 37 Z 38
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 3218
PERSONNEL INJURIES NUMBER DESCRIPTION (41) NA
0 0 0 40
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 3219
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43) NA
Z 42
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 3220
PUBLICITY ISSUED DESCRIPTION (45) NA
N 46
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

NAME OF PREPARER

H. B. RAY

PHONE

714/492-7700

NRC USE ONLY