

Duke Power Company  
Nuclear Production Dept  
P.O. Box 1007  
Charlotte, N.C. 28201-1007

M.S. TUCKMAN  
Vice President  
Nuclear Operations  
(704)373-3851



**DUKE POWER**

August 12, 1991

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Subject: Catawba Nuclear Station  
Docket Nos. 50-413 and 50-414  
Revision to Proposed TS Amendment  
TS 3.6.1.8, 3.7.6, 3.9.4, 3.9.11, and 3.7.7

My letter dated April 8, 1991 submitted a proposed amendment to Technical Specifications (TS) 3.6.1.8, 3.7.6, 3.9.4, 3.9.11, and 3.7.7. Per discussions with your staff clarifying statements have been added to both the TS and the Bases.

Because of the need for timely approval, the request to indicate a bypass leakage criteria of 1% in TS 4.6.1.8.b.1, 4.6.1.8.e, 4.6.1.8.f, 4.9.11.2.b.1, 4.9.11.2.e, 4.9.11.2.f, 4.7.7.b.1, 4.7.7.e, and 4.7.7.f is being withdrawn. This change will be resubmitted at a later date with additional justification.

The marked up TS pages, as described above, are attached.

Very truly yours,

A handwritten signature in cursive script that reads 'M. S. Tuckman'.

M. S. Tuckman

ADD 1/1

U. S. Nuclear Regulatory Commission  
August 12, 1991  
Page 2

xc: S. D. Ebnetter  
Regional Administrator, Region II

R. E. Martin, ONRR

✓ W. T. Orders,  
Senior Resident Inspector

Heyward Shealy, Chief  
Bureau of Radiological Health SC

American Nuclear Insurers

M & M Nuclear Consultants

INPO Records Center