



Entergy Operations, Inc.
River Bend Station
5485 U.S. Highway 61
PO Box 220
St. Francisville, LA 70775
(504) 336-6225
FAX (504) 635-5068

JAMES J. FISICARO
Director
Nuclear Safety

September 30, 1994

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Stop P1-37
Washington, DC 20555

Subject: River Bend Station - Unit 1
Docket No. 50-458
License No. NPF-47
License Amendment Request (LAR) 94-10 - Change to Technical
Specification 3/4.2.2, APRM Setpoints

File Nos: G9.5, G9.42


RBG-40915
RBF1-94-0057

The purpose of this letter is to address a question raised by the NRC pertaining to License Amendment Request (LAR) 94-10, "Change to Technical Specification 3/4.2.2, APRM Setpoints." River Bend Station (RBS) submitted LAR 94-10 via RBG-40868, dated September 12, 1994.

RBS and NRC personnel discussed LAR 94-10 in a conference call held on September 28, 1994. In the discussion, the NRC asked if any RBS safety analysis takes credit for the Average Power Range Monitor (APRM) flow-bias scram and requested a letter answering the question. After reviewing the safety analyses and conferring with General Electric, RBS has concluded that the current safety analyses take no credit for the APRM flow-bias scram.

If you have any further questions regarding this request, please contact me or my staff.

Sincerely,


JJF/OPB/GHD

120006
9410120070 940930
PDR ADDCK 05000458
P PDR

ADD 1/0

License Amendment Request (LAR) 94-10
September 30, 1994
RBG-40915
RBF1-94-0057
Page 2 of 2

cc: NRC Resident Inspector
P. O. Box 1051
St. Francisville, LA 70775

Mr. Robert Schaaf
U. S. Nuclear Regulatory Commission
M/S OWFN 13-H-15
Washington, DC 20555

U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011