



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Nuclear Department

August 18, 1983

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, Maryland 20014

Attention: Mr. Steven A. Varga, Chief
Operating Reactors Branch 1
Division of Licensing

Gentlemen:

INOPERABLE CENTRIFUGAL CHARGING PUMP
NO. 1 UNIT
SALEM GENERATING STATION
DOCKET NOS. 50-272

In our letter dated August 17, 1983, we indicated that final coupling alignment and testing on No. 11 centrifugal charging pump might not be completed within the allotted 72 hour Limiting Condition for Operation ACTION requirement of Technical Specification 3.5.2.a.

Contrary to the above, the work on No. 11 CCP was completed and the pump was declared operable at 0800, August 18, 1983.

We hereby withdraw our request for an extension of the LCO requirement.

Very truly yours,

E A Liden/482

E. A. Liden
Manager - Nuclear
Licensing and Regulation

8308250293 830818
PDR ADOCK 05000272
P PDR

The Energy People

IE29