



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

83 AUG 23 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-070/0 - Fire
Rated Doors Blocked Open to
Support Planned Maintenance
Activities
AECM-83/0477

Beginning on July 16, 1983, the following fire rated doors were blocked open to support planned maintenance activities in areas of the Auxiliary and Control Buildings:

1A320 - EL 139'	Steam Tunnel, Auxiliary Building
OC211 - EL 111'	Division II Switchgear Entrance, Control Building
OC710 - EL 189'	Corridor to Upper Cable Room, Control Building
1A306 - EL 139'	Division I Switchgear, Auxiliary Building
1A109 - EL 93'	RHR "C" Pump Room, Auxiliary Building
1A202 - EL 119'	RHR "B" Piping Room, Auxiliary Building
1A107 - EL 93'	Stairwell Southwest Corner, Auxiliary Building
1A212 - EL 119'	Division II Switchgear, Auxiliary Building

Fire watches were established in accordance with Technical Specification 3.7.7 as part of the planned activities. The doors are expected to be restored by September 30, 1983. This is submitted as a Special Report pursuant to Technical Specification 6.9.2.

Yours truly,

L. F. Dale
Manager of Nuclear Services

8308260040 830819
PDR ADOCK 05000416
S PDR

EBS/SHH:sap

cc: (See Next Page)

Member Middle South Utilities System

OFFICIAL COPY

IE 22 1/0

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0477

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555