



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

August 17, 1983: 45

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station

Unit 1

Docket No. 50-416

License No. NPF-13

File 0260/L-835.0

Special Report 83-068/0 - Fire

Rated Doors Blocked Open to

Support Planned Maintenance

Activities

AECM-83/0467

On July 11, 1983, the following fire rated doors were blocked open to support planned maintenance activities:

OC221 - Elevation 111'

West Stairwell, Control Building

OC115 - Elevation 93'

Instrument Shop, Control Building

Fire watches were established in accordance with Technical Specification 3.7.7 until the doors were restored on August 9, 1983.

This is reported as a Special Report pursuant to Technical Specification 6.9.2 since the seven (7) day Limiting Condition for Operation time limit was exceeded. The event had no affect on the health and safety of the public and did not constitute a threat to plant safety. This is submitted as a final report.

Yours truly,

L. F. Dale

Manager of Nuclear Services

EBS/SHH:sap

cc: (See Next Page)

8308260111 830817
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

IE 22
1/0

MISSISSIPPI POWER & LIGHT COMPANY

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555