



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

August 23 1983 10:45

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Special Report 83-069/0 - Fire  
Rated Barriers Opened to  
Support Planned Maintenance  
Activities  
AECM-83/0469

Beginning on July 12, 1983, the following barriers were opened to support planned maintenance activities:

PENETRATIONS

CE418B  
AE169D  
AE101C  
CE10G

CABLE TRAY COVER

1ADTWI47

ACCESS HATCH

Room 1A127 (Radwaste Tunnel)

Hourly fire watches were established within one (1) hour and will be maintained for the duration of the planned maintenance activities in accordance with Technical Specification 3.7.7. This is reported as a Special Report pursuant to Technical Specification 6.9.2.

This condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. The work tasks are expected to be complete by November 30, 1983.

Yours truly,

L. F. Dale  
Manager of Nuclear Services

8308260133 830817  
PDR ADDCK 05000416  
S PDR

EBS/SHH:sap

cc: (See Next Page)

Member Middle South Utilities System

OFFICIAL COPY

IE 22 1/0

## MISSISSIPPI POWER &amp; LIGHT COMPANY

cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555