

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MIDCC2200-00000-00341111415

CON'T 01 REPORT SOURCE L605000316707268380817839

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 DURING NORMAL OPERATION FOLLOWING A SURVEILLANCE TEST, CHANNEL 2 OF CONTAINMENT PRES-
03 SURE INDICATION FAILED LOW. THIS IS NON-CONSERVATIVE IN RESPECT TO TECHNICAL SPECIFI-
04 CATION TABLE 3.3-3 ITEMS 1.c, 2.c, 3.b.3 AND 4.c. THE ACTION REQUIREMENTS WERE MET AS
05 THE APPROPRIATE BISTABLES WERE TRIPPED AND THE REMAINING CONTAINMENT PRESSURE CHANNELS
06 WERE VERIFIED TO BE OPERABLE. PREVIOUS OCCURRENCES INCLUDE: 50-315/82-99. THE HEALTH
07 AND SAFETY OF THE PUBLIC WERE NOT AFFECTED.

08 09

09 SYSTEM CODE IB11 CAUSE CODE E12 CAUSE SUBCODE X13 COMPONENT CODE INSTRU14 COMP SUBCODE S15 VALVE SUBCODE Z16

17 LER-RO REPORT NUMBER 83 EVENT YEAR 123 SEQUENTIAL REPORT NO. 070 OCCURRENCE CODE 03 REPORT TYPE L31 REVISION NO. 032

ACTION TAKEN B13 FUTURE ACTION Z19 EFFECT ON PLANT Z20 SHUTDOWN METHOD Z21 HOURS 0000 ATTACHMENT SUBMITTED N22 NPD-4 FORM SUB Y24 PRIME COMP. SUPPLIER N25 COMPONENT MANUFACTURER C77047

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 INVESTIGATION REVEALED THAT A TOGGLE SWITCH (MFG BY CUTLER-HAMMER, MDL MS 25308-232)
11 IN THE TEST CIRCUIT HAD DIRTY CONTACTS. THE TOGGLE SWITCH WAS CLEANED AND EXERCISED.
12 IT WAS FOUND TO FUNCTION PROPERLY AND THE CONTAINMENT PRESSURE CHANNEL WAS RETURNED TO
13 SERVICE. ON 02-27-83, THE TOGGLE SWITCH WAS REPLACED AS A PRECAUTIONARY MEASURE. THE
13 CONTAINMENT PRESSURE CHANNEL WAS REMOVED FROM SERVICE AND THE SWITCH WAS REPLACED.

15 FACILITY STATUS E28 % POWER 10029 OTHER STATUS NA30 METHOD OF DISCOVERY A31 DISCOVERY DESCRIPTION OPERATOR OBSERVATION32

16 ACTIVITY CONTENT Z33 RELEASED OF RELEASE Z34 AMOUNT OF ACTIVITY NA35 LOCATION OF RELEASE NA36

17 PERSONNEL EXPOSURES NUMBER 00037 TYPE Z38 DESCRIPTION NA39

18 PERSONNEL INJURIES NUMBER 00040 DESCRIPTION NA41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z42 DESCRIPTION NA43

20 PUBLICITY ISSUED DESCRIPTION N44 NA45

8308260193 830817
PDR ADOCK 05000316
S PDR

NRC USE ONLY

NAME OF PREPARER J. L. RISCHLING

PHONE 616-465-5901