

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

October 11, 1994

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 94-594
NL&P/EJW
Docket No. 50-338
License No. NPF-4


Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT 1
STEAM GENERATOR TUBE PLUGGING REPORT

North Anna Unit 1 recently completed its 1994 refueling outage. During the outage, eddy current examinations were conducted for fifty percent of the tubes in steam generators "A" and "C." Technical Specification 4.4.5.5.a, requires a listing of those tubes plugged during the outage to be provided within 15 days of completion. However, no tubes were plugged as a result of these examinations.

Should you have any questions or require additional information, please contact us.

Very truly yours,



M. L. Bowling, Manager
Nuclear Licensing and Programs

cc: U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W.
Suite 2900
Atlanta, GA 30323

Mr. R. D. McWhorter
NRC Senior Resident Inspector
North Anna Power Station

*Accol
1/0*