

TS 6.9.1.e



PECO ENERGY

PECO Energy Company
Nuclear Group Headquarters
965 Chesterbrook Boulevard
Wayne, PA 19087-5691

October 13, 1994

Docket No. 50-277

License No DPR-44

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: Peach Bottom Atomic Power Station, Unit 2
Issuance of the Core Operating Limits Report
for Reload 10, Cycle 11

Dear Sir:

Enclosed is a copy of the Core Operating Limits Report (COLR) for Peach Bottom Atomic Power Station (PBAPS), Unit 2, Reload 10, Cycle 11.

This report provides the cycle-specific parameter limits for: Maximum Average Planar Linear Heat Generation Rate (MAPLHGR); Minimum Critical Power Ratio (MCPR); ARTS MCPR thermal limit adjustments and multipliers; ARTS MAPLHGR thermal limit multipliers; Linear Heat Generation Rate (LHGR); Rod Block Monitor (RBM) setpoints; and a Single Loop Operation (SLO) MCPR adjustment for PBAPS Unit 2, Cycle 11 (Reload 10) operation.

These values have been determined using NRC-approved methodology and are established such that all applicable limits of the plant safety analysis are met.

This report is being submitted to the NRC in accordance with the PBAPS Unit 2 Technical Specifications Section 6.9.1.e.

If you have any questions concerning this submittal, please contact us.

Sincerely,

G. A. Hunger, Jr.
G. A. Hunger, Jr., Director
Licensing Section

Enclosure

cc: T. T. Martin, Administrator, Region I, USNRC
W. L. Schmidt, Senior Resident Inspector, USNRC, PBAPS

2100

9410210202 941013
PDR ADDCK 05000277
P PDR

Good