



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

JOHN E. MAIER
Vice President

TELEPHONE
AREA CODE 716 546-2700

August 5, 1983

Dr. Thomas E. Murley, Regional Administrator
U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Subject: IE Bulletin No. 82-02
Response To Action Item 4
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Dr. Murley:

This submittal is forwarded in response to Action Item 4 of IE Bulletin No. 82-02. In regard to Action Item 4a, Action Item 1 has been completed for the specific items identified within the scope of this bulletin and as necessary, maintenance procedures have been revised to provide specific requirements for torquing, tolerances, disassembly, reassembly, gasket installation, lubrication and cleanliness. The maintenance training program addresses training of appropriate personnel in proper torquing techniques, in addition to the procedural torquing requirements. The Ginna Station Quality Assurance Program provides measures for proper selection and use of fastener lubricants and injection sealant compounds to minimize fastener susceptibility to stress corrosion cracking.

In response to Action Item 4b and 4c, the attached report identifies Reactor Coolant Pressure boundary components identified in the scope of the IE Bulletin No. 82-02, that were opened during the outage in October 1982, and the refueling outage 1983.

Very truly yours,

J. E. Maier

8309070275 830805
PDR ADOCK 05000244
Q PDR

Subscribed and sworn to me
on this 4th day of August 1983.

WILLIS L. SCHULZE

NOTARY PUBLIC, State of N.Y., Monroe County
My Commission Expires March 30, 1985

FEH
111

ATTACHMENT TO IE BULLETIN 82-02 RESPONSE FOR ACTION ITEMS 4B AND 4C

<u>Reactor Coolant Pressure Boundary</u>	<u>Date Inspected</u>	<u>Examination Performed</u>	<u>Results</u>
Pressurizer Manway	5/25/83	Visual-Removed	No Degradation
"A" Steam Generator Primary Manways	5/17/83	Visual-Removed	No Degradation
"D" Steam Generator Primary Manways	5/26/83	Visual-Removed	No Degradation
PCV-431C, Pressurizer Power Operated Relief Valve	10/15/82	Visual-In Place	No Degradation
MOV-515 Pressurizer Power Operated Relief Guard Valve	10/18/82	Visual-Removed	No Degradation
RV-434 Pressurizer Safety Valve	04/07/83	Visual-Removed	No Degradation
RV-435 Pressurizer Safety valve	04/07/83	Visual-Removed	No Degradation



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

JOHN E. MAIER
Vice President

TELEPHONE
AREA CODE 716 546-2700

August 5, 1983

Director of Nuclear Reactor Regulation
Attention: Mr. Dennis M. Crutchfield, Chief
Operating Reactor Branch No. 5
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Shift Staffing Criteria
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. Crutchfield:

Re: RG&E Letter of February 1, 1982 from John E. Maier to NRC
Dennis M. Crutchfield

This letter is to amend Rochester Gas and Electric Corp.'s letter of February 1, 1982 on Shift Staffing Criteria from John E. Maier. In the letter of February 1, 1982, we stated that based on our licensing plans and present licensed operators, we anticipated having sufficient licenses by September 1983.

Our present license exam has been changed from July 1983 to October 1983 due to work and examination scheduling. The class consists of four SRO license candidates and four RO license candidates from the Operations Section.

Rochester Gas and Electric Corp. would like to postpone the Shift License requirement for each shift to January 1, 1984.

An earlier commitment date would continue to require inappropriate amounts of overtime of licensed operations personnel for vacations, illness and training.

Very Truly Yours,

John E. Maier
John E. Maier

8308160448