



Log # TXX-94279  
File # 916 (3/4.3)  
10010  
Ref. # 10CFR50.90  
10CFR50.36

October 20, 1994

C. Lance Terry  
Group Vice President

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
DOCKET NOS. 50-445 AND 50-446  
LICENSE AMENDMENT REQUEST 94-015  
SUPPLEMENTAL INFORMATION

REF: TU Electric letter logged TXX-94131 dated  
September 19, 1994, from C. L. Terry to the USNRC

Gentlemen:

By the above reference, TU Electric provided License Amendment Request 94-015 to the NRC regarding a one-time extension of Emergency Diesel Generator and other related Surveillance Requirements from 18 to 24 months. Following review and subsequent discussions with the NRC staff, the following supplemental information is being provided:

- 1) Add "(but not to exceed)" before 24 months on page 3/4 3-36 for Table 4.3-2 to clarify TU Electric's intent not to extend the surveillance interval beyond 24 months, as would normally be allowed per specification 4.0.2.
- 2) TU Electric has verified that the Surveillance Requirements for which TU Electric is requesting a one-time extension of the surveillance interval in this LAR were indeed performed during the Unit 2 mid-cycle outage.

The change in item 1 above is reflected in the attached mark-up (see Attachment 2). This supplemental information clarifies the meaning of the original license amendment request and does not change its intent or technical meaning.

In accordance with 10CFR50.91(b), TU Electric is providing the State of Texas with a copy of this requested amendment.

050149


9410260246 941020  
PDR ADOCK 05000445  
P PDR

A001  
1/4

TXX-94279  
Page 2 of 2

Should you have any questions, please contact Mr. Alan Quam at (817) 897-8621 or Mr. Manu C. Patel at (214) 812-8298.

Sincerely,

  
C. L. Terry

ADQ/gp

Attachments:      1.      Affidavit  
                         2.      Affected Technical Specification pages (NUREG-1468)

cc - Mr. L. J. Callan, Region IV  
      Mr. D. D. Chamberlain, Region IV  
      Resident Inspectors, CPSES (2)  
      Mr. T. J. Polich, NRR

Mr. D. K. Lacker  
Bureau of Radiation Control  
Texas Department of Public Health  
1110 West 49th Street  
Austin, Texas 78704

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
 )  
Texas Utilities Electric Company ) Docket Nos. 50-445  
 ) and 50-446  
(Comanche Peak Steam Electric )  
Station, Unit 1 & 2 )

AFFIDAVIT

C. L. Terry being duly sworn, hereby deposes and says that he is Group Vice President, Nuclear Production of TU Electric, the licensee herein; that he is duly authorized to sign and file with the Nuclear Regulatory Commission this supplemental information to License Amendment Request 94-015 to the CPSES Unit 1 Operating License (NPF-87) and CPSES Unit 2 Operating License (NPF-89); and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.



C. L. Terry  
Group Vice President,  
Nuclear Production

STATE OF TEXAS )  
 )  
COUNTY OF Somervell )

Subscribed and sworn to before me, on this 20 day of October, 1994.



Notary Public

