

ATTACHMENT 2 TO TXX-94279
AFFECTED TECHNICAL SPECIFICATION PAGE
(NUREG-1468)

Page 3/4 3-36

TABLE 4.3-2 (Continued)
ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

CHANNEL FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	ANALOG CHANNEL OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MASTER RELAY TEST	SLAVE RELAY TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED
7. Automatic Initiation of ECCS Switchover to Containment Sump (Continued)								
b. RWST Level--Low-Low Coincident With Safety Injection	S	SR	Q	N.A.	N.A.	N.A.	N.A.	1, 2, 3, 4
	See Item 1. above for all Safety Injection Surveillance Requirements.							
3/4 3-36 B. Loss of Power (6.9 kV & 480 V Safeguards System Undervoltage)								
a. 6.9 kV Preferred Offsite Source Undervoltage	N.A.	R *	N.A.	(3, 2)	N.A.	N.A.	N.A.	1, 2, 3, 4
b. 6.9 kV Alternate Offsite Source Undervoltage	N.A.	R *	N.A.	(3, 2)	N.A.	N.A.	N.A.	1, 2, 3, 4
c. 6.9 kV Bus Under- voltage	N.A.	R *	N.A.	(3, 2)	N.A.	N.A.	N.A.	1, 2, 3, 4
d. 6.9 kV Degraded Voltage	N.A.	R *	N.A.	(3, 2)	N.A.	N.A.	N.A.	1, 2, 3, 4
e. 480 V Degraded Voltage	N.A.	R *	N.A.	(3, 2)	N.A.	N.A.	N.A.	1, 2, 3, 4
f. 480 V Low Grid Undervoltage	N.A.	R *	N.A.	(3, 2)	N.A.	N.A.	N.A.	1, 2, 3, 4

* This surveillance test interval is extended to (but not to exceed) 24 months for Train A, Unit 2, to remain in effect until the completion of the second refueling outage for Unit 2.

COMANCHE PEAK - UNITS 1 AND 2

Unit 1 - Amendment No. 13