

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Seldon Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 666-6911

June 30, 1983

Docket No. 50-423
B10830

Director of Nuclear Reactor Regulation
Mr. B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

- References: (1) D. G. Eisenhower letter to W. G. Council, Acceptance Review of the Application for an Operating License for Millstone Unit No. 3, dated January 31, 1983.
- (2) W. G. Council letter to B. J. Youngblood, Millstone Nuclear Power Station, Unit No. 3: Response to the Requests for Additional Information that Resulted from the Acceptance Review, dated March 31, 1983.

Millstone Nuclear Power Station, Unit No. 3
Responses Related to the Operating License Application

In Reference (2) Northeast Nuclear Energy Company (NNECO) as applicant for an operating license for Millstone Nuclear Power Station, Unit No. 3 submitted our responses to your requests for additional information that resulted from your acceptance review. In cases where we were unable to provide a complete response at that time we committed to submit the additional information in subsequent amendments to our OL application.

The items for which we committed to supply additional information are:

ER Questions

Q 240.1 (Section 2.4)
QE 100.2

FSAR Questions

Q 220.6 (Section 3.8.4.4)
Q 220.7 (Section 3.8.4.8)
Q 440.2 (Section 5.2.2.2)
Q 440.7 (Section 15.0)
Enclosure 4, Item 3
Enclosure 4, Item 4
Enclosure 4, Item 5

*13001
1/13
Limited
Dist*

Q 440.2 (Section 5.2.2.2)

In our response to Question No. Q 440.2 we state that "Details of safety valve sizing and resultant overpressure analyses are provided in the Millstone 3 Overpressure Protection Report per Article NB-7300 of the ASME Code, Section III."

Attached are 3 copies of the "Overpressure Protection Report for Millstone Nuclear Power Plant Unit 3 as required by ASME Boiler and Pressure Vessel Code Section III, Article NB-7300, March 1983."

Q 440.7 (Section 15.0)

The response to this question will be provided in September 1983.

Enclosure 4, Item 3

The requested information requires detailed information on the displays for Inadequate Core Cooling (ICC) Instrumentation. Since ICC instrumentation readouts and data acquisition are an integral part of the Safety Parameter Display System (SPDS) we could not address this question until the schedule for the SPDS implementation had been determined. Therefore, details for the display instrumentation for ICC will be provided as an amendment in September, 1983.

Enclosure 4, Item 4 and

Question No. Q 250.1 (Section 5.2.4.8)

Attached are 3 copies of "Millstone Point Unit 3, Pre-Service Inspection Plan, Document No: PSI 2.01, Rev. 1" This PSI program plan description is forwarded as we committed in our response to Enclosure 4, Item 4 and Question No. Q 250.1 of NRC's request for additional information.

Enclosure 4, Item 5

A Preoperational Snubber Program has been prepared by Northeast Nuclear Energy Company (NNECO) and is currently undergoing review prior to submittal to NRC. The program consists of various specifications and procedures designed to protect snubbers from damage and provide adequate surveillance to detect damage, thus ensuring snubber operability during plant startup. These procedures will be provided in FSAR Chapter 14 as an amendment in September, 1983.

If you have any concerns related to commitments contained herein or any questions related to our responses, please contact our licensing representative directly.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY, Et Al

By NORTHEAST NUCLEAR ENERGY COMPANY,
Their Agent

W. G. Council
Senior Vice President

STATE OF CONNECTICUT)
COUNTY OF HARTFORD) ss. Berlin

Then personally appeared before me W. G. Council, who being duly sworn, did state that he is Senior Vice President of Northeast Nuclear Energy Company, applicant herein, that he is authorized to execute and file the foregoing information in the name and on behalf of the applicants herein and that the statements contained in said information are true and correct to the best of his knowledge and belief.

Lorraine J. D'Amico
Notary
My Commission Expires March 31, 1988