



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

83 SEP 2 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-022/1 -
Update Report - Fire Break
in a Cable Tray Removed
AECM-83/0524

This is an update to a previous report submitted on April 21, 1983. The event for which the report was submitted occurred on March 17, 1983, when a fire break in a cable tray, at elevation 177 feet of the Control Building, was removed for implementation of a design change work package. An hourly fire watch was established in accordance with Technical Specification 3.7.7.

The fire break has been restored and the Limiting Condition for Operation was lifted on August 23, 1983. This is a Special Report submitted pursuant to Technical Specification 6.9.2. This is a final report.

Yours truly,

L. F. Dale
for L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee

Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL

8309070394 830831
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

1/0