

50-352
353

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

EDWARD G. BAUER, JR.
VICE PRESIDENT
AND GENERAL COUNSEL

(215) 841-4000

EUGENE J. BRADLEY
ASSOCIATE GENERAL COUNSEL

DONALD BLANKEN
RUDOLPH A. CHILLEM
E. C. KIRK HALL
T. H. MAHER CORNELL
PAUL AUERBACH

ASSISTANT GENERAL COUNSEL
EDWARD J. CULLEN, JR.
THOMAS H. MILLER, JR.
IRENE A. McKENNA
ASSISTANT COUNSEL

July 13, 1983

Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Limerick Generating Station, Units 1&2
Response to Core Performance Branch
Draft Safety Evaluation Report


References: 1) A. Schwencer to E. G. Bauer, Jr.,
letter dated March 11, 1983
2) E. J. Bradley to A. Schwencer letter
dated May 25, 1983

File: GOVT 1-1 (NRC)

Dear Mr. Schwencer:

The attached document is a revised draft response to Core Performance Branch Draft Safety Evaluation Report Item No. 10, "Post-Irradiation Surveillance". The information contained on this draft response will be incorporated into the FSAR, exactly as it appears on the attachments, in the revision scheduled for August, 1983.

Sincerely,


Eugene J. Bradley

RJS/gra/11

Copy to: See Attached Service List

8307180054 830713
PDR ADOCK 05000352
E PDR

B001
1/1

cc: Judge Lawrence Brenner (w/o enclosure)
Judge Richard F. Cole (w/o enclosure)
Judge Peter A. Morris (w/o enclosure)
Troy B. Conner, Jr., Esq. (w/o enclosure)
Ann P. Hodgdon (w/o enclosure)
Mr. Frank R. Romano (w/o enclosure)
Mr. Robert L. Anthony (w/o enclosure)
Mr. Marvin I. Lewis (w/o enclosure)
Judith A. Dorsey, Esq. (w/o enclosure)
Charles W. Elliott, Esq. (w/o enclosure)
Jacqueline I. Ruttenberg (w/o enclosure)
Thomas Y. Au, Esq. (w/o enclosure)
Mr. Thomas Gerusky (w/o enclosure)
Director, Pennsylvania Emergency Management Agency (w/o enclosure)
Mr. Steven P. Hershey (w/o enclosure)
Donald S. Bronstein, Esq. (w/o enclosure)
Mr. Joseph H. White, III (w/o enclosure)
David Wersan, Esq. (w/o enclosure)
Robert J. Sugarman, Esq. (w/o enclosure)
Martha W. Bush, Esq. (w/o enclosure)
Spence W. Perry, Esq. (w/o enclosure)
Atomic Safety and Licensing Appeal Board (w/o enclosure)
Atomic Safety and Licensing Board Panel (w/o enclosure)
Docket and Service Section (w/o enclosure)

DRAFT SAFETY EVALUATION REPORT ITEMS
CORE PERFORMANCE BRANCH

Question (10) - Post-Irradiation Surveillance

A general post-irradiation surveillance program for fuel assemblies that meets the guidelines of Paragraph II.D.3 of Section 4.2 of the Standard Review Plan (NUREG-0800) should be provided. A plan similar to that proposed for WNP-2 and Perry would be acceptable.

Response

The following post-irradiation fuel surveillance program is intended to conform with the objectives of the SRP:

Routine visual inspection of representative (usually discharged) fuel will be performed in connection with each refueling outage. Additional examinations will be performed if warranted by those visual inspections, activity indications, or other factors.