

ROBERT E. DENTON
Vice President
Nuclear Energy

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 586-2200 Ext. 4455 Local
410 260-4455 Baltimore



October 26, 1994

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
Temporary Relief Request from the American Society of Mechanical Engineers
(ASME) Code Requirements to Delay Repair of Leak in Two Spent Fuel Pool
Cooling System Valves, Calvert Cliffs Nuclear Power Plant, Unit 1 (TAC
No. 88835) and Unit 2 (TAC No. 88836)

REFERENCES: (a) Letter from Mr. D. G. McDonald, Jr. (NRC) to Mr. R. E. Denton (BGE),
dated July 14, 1994, same subject

In the referenced letter, temporary relief was granted from the ASME Code, Section XI, Article IWA-5250, to repair leaks in the bodies of two throttle valves located in the spent fuel pool cooling system. This is to inform you that the subject valves have been replaced, thereby completing our actions associated with this temporary relief.

Should you have any further questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

for
R. E. Denton
Vice President - Nuclear Energy

RED/NH/dlm

A001
1/0

9411020090 941026
PDR ADDCK 05000317
PDR

Document Control Desk

October 26, 1994

Page 2

cc: D. A. Brune, Esquire
J. E. Silberg, Esquire
L. B. Marsh, NRC
D. G. McDonald, Jr., NRC
T. T. Martin, NRC
P. R. Wilson, NRC
R. I. McLean, DNR
J. H. Walter, PSC