



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

September 7, 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-015/3 -
Update Report - Fire Rated
Penetrations Found Open
AECM-83/0543

This is an update to previous reports submitted under Special Report No. 83-015 on April 8, 1983, May 19, 1983, and June 15, 1983. The purpose of this update is to provide a revised estimated completion date. The original report identified three open penetrations that were a result of incomplete design drawings or construction oversight. Currently, action statement (a) of Technical Specification 3.7.7 is being implemented and will continue to be implemented until all three penetrations are sealed per design requirements. Material Nonconformance Report's were initiated to correct the deficiencies and presently only one Material Nonconformance Report has been dispositioned. Work to seal the penetration that has been dispositioned is currently in progress. The restoration date for the penetrations is being revised to October 15, 1983. This is considered a final report unless the completion date is not met.

Yours truly,

L. F. Dale

for

L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap

cc: (See Next Page)

OFFICIAL COPY

8309150395 830907
PDR ADOCK 05000416
S PDR

IE 22
1/0

Member Middle South Utilities System

MISSISSIPPI POWER & LIGHT COMPANY

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555