

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 ALJMF2 000-000000-000 341111 4 5
7 8 9 14 15 25 26 30 37 38

CONT

01 REPORT SOURCE L 6 05000364 7 081083 8 090883 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 At 0130 on 8/10/83, during the performance of FNP-2-STP-80.1 (Diesel Generator 2B
03 Operability Test), Diesel Generator 2B was declared inoperable when it failed to
04 start. Tech. Spec. 3.8.1.1, in part, requires Diesel Generator 2B to be operable.
05 Tech. Spec. 3.8.1.1 action statement requirements were met. Health/safety of the
06 public was not affected. This is the first failure in the last 100 valid tests.
07
08

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
E E 11 E 12 B 13 E N G I N E 14 Z 15 Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20
17 LER/NO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
8 3 0 3 3 0 3 L 0
21 22 23 24 25 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
A 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 A 25 F 0 1 0
33 34 35 36 37 38 39 40 41 42 43 44 45

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 No immediate cause for this event could be determined. The diesel was inspected
11 and successfully test started. Following satisfactory completion of FNP-2-STP-
12 80.1, Diesel Generator 2B was declared operable at 0529 on 8/10/83. Subsequent
13 investigation revealed excessive bushing and rotor wear on the #1 starting air
14 distributor. The distributor was replaced.

15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
E 28 1 0 0 29 NA B 31 Surveillance Test
7 8 9 10 11 12 13 14 15 16 17 18 19 20
16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
Z 33 Z 34 NA NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20
17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
0 0 0 37 Z 38 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20
18 PERSONNEL INJURIES NUMBER DESCRIPTION 41
0 0 0 40 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20
19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
Z 42 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20
20 PUBLICITY ISSUED DESCRIPTION 45
N 44 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20

8309190075 830908
PDR ADOCK 05000348
S PDR

NAME OF PREPARER W. G. Hairston, III

PHONE: (205) 899-5156