

## Attachment to AECM-83/0505

**PE ALL REQUIRED**

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	4	1	6	7	0	1	1	3	8	3	18	0	9	0	8	8	3	9
60	61	DOCKET NUMBER						68	69	EVENT DATE						74	75	REPORT DATE						80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On January 13, 1983, fire rated door DC104 (Hot Machine Shop to Turbine Bldg.) was blocked open to route a temporary discharge hose from the Hot Machine Shop sump to the Turbine Bldg floor drain system. An hourly fire watch was established in accordance with T.S.3.7.7. The event had no effect on the health & safety of the public & did not constitute a threat to plant safety. This is submitted as a Special Report pursuant to T.S.6.9.2.

SYSTEM CODE A B 11		CAUSE CODE X 12		CAUSE SUBCODE Z 13		COMPONENT CODE Z Z Z Z Z Z 14		COMP. SUBCODE Z 15		VALVE SUBCODE Z 16	
EVENT YEAR B 3 21 22		SEQUENTIAL REPORT NO. 0 3 1 24 25 26		OCCURRENCE CODE 9 9 28 29		REPORT TYPE X 30		REVISION NO. 2 32		COMPONENT MANUFACTURER Z 9 9 9 44 47	
ACTION TAKEN: FUTURE ACTION X 18 X 19 33 34		EFFECT ON PLANT Z 20 35		SHUTDOWN METHOD Z 21 36		HOURS 0 0 0 0 22 37 38 39		ATTACHMENT SUBMITTED N 23 41		NPRD-4 FORM SUB. N 24 42	
PRIME COMP. SUPPLIER Z 25 43		CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27		PRIME COMP. SUPPLIER Z 25 43		PRIME COMP. SUPPLIER Z 25 43		PRIME COMP. SUPPLIER Z 25 43		PRIME COMP. SUPPLIER Z 25 43	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10	The temporary discharge hose was routed through the doorway to discharge
11	water from the Hot Machine Shop sump. The present system pump is inade-
12	quate (will not generate required head). A DCR has been initiated for
13	pump replacement. In the interim, the door will be open & fire watches
14	will be established as required. Est. restoration is by December 1983.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	6	28	0	0	0	29	A	31
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	2	33	2	34	NA	35	NA	36
PERSONNEL EXPOSURES		TYPE		DESCRIPTION					
1	7	0	0	0	37	2	38	NA	39
PERSONNEL INJURIES		TYPE		DESCRIPTION					
1	8	0	0	0	40	NA	41		42
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	2	42	NA	43		44		45
PUBLICITY		TYPE		DESCRIPTION					
2	0	N	44	NA	45		46		47

8309190166 830908  
PDR ADOCK 05000416  
S PDR

NRC USE ONLY

NAME OF PREPARER

Ron Byrd

**PHONE:**

NRC USE ONLY

026-16 0d5



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

83 SEP 15 P 1: 36  
September 8, 1983

NUCLEAR PRODUCTION DEPARTMENT

U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Update Report - Fire Rated Door  
OC104 Blocked Open to Route Hose  
LER 83-031/99 X-2  
AECM-83/0505

This is an update to previous reports submitted on February 18, 1983, and May 9, 1983. The event for which the report was submitted occurred on January 13, 1983, when fire rated door OC104 was blocked open to route a temporary discharge hose from the Hot Machine Shop sump to the Turbine Building floor drain system. An hourly fire watch was established in accordance with Technical Specification 3.7.7. The event was reported pursuant to Technical Specification 6.9.2.

The purpose of this report is to revise the estimated date of restoration to December, 1983. Attached is LER 83-031/99 X-2 which is a final report.

Yours truly,

*L. F. Dale*

for L. F. Dale  
Manager of Nuclear Services

EBS/SHH:rg

Attachment

cc: See next page

OFFICIAL COPY

IF 22



## MISSISSIPPI POWER &amp; LIGHT COMPANY

cc: Mr. J. B. Richard (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555