

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

July 11, 1983  
LOZ-83-0079

J. WILLIAMS, JR.  
SENIOR VICE PRESIDENT  
NUCLEAR OPERATIONS

Docket No. 50-358

U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Attention: Mr. J.G. Keppler  
Regional Administrator

Gentlemen:

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1  
10CFR50.55(e), ITEM M-14 - HVAC DAMPER  
ACTUATOR DEFICIENCIES  
W.O. 57300, JOB E-5590, FILE NO. 956C, M-14

This letter constitutes an interim report concerning the subject condition initially reported to the Commission on March 12, 1980 under the requirements of 10CFR50.55(e).

As indicated in our previous report, LCZ-83-0005, dated March 24, 1983, actual field torque measurements on the dampers and analysis of the torque data by Sargent & Lundy Engineers has determined that:

- 1.) Three actuators require replacement;
- 2.) Two actuators require spring replacement; and
- 3.) Three actuators require spring height adjustment.

Torque test and analysis are still required on ten (10) dampers in the Primary Containment Ventilation (VP) and Primary Containment Purge (VQ) systems. These tests cannot be performed until the VP and VQ system ductwork is complete. Completion of this work is contingent upon the release of the NRC November 12, 1982 "Order to Show Cause and Order Immediately Suspending Construction" for work in this area. Upon this release, a projected schedule for completion of the corrective actions will be submitted.

8307210040 830711  
PDR ADOCK 05000358  
S PDR

JUL 18 1983


IE 7/10

Mr. J.G. Keppler  
Regional Administrator  
July 11, 1983  
LOZ-83-0079  
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By   
J. WILLIAMS, JR.  
SENIOR VICE PRESIDENT

DJS/sfr

cc: NRC Office of Inspection & Enforcement  
Washington, D.C. 20555  
NRC Senior Resident Inspector  
ATTN: W.F. Christianson  
NRC Zimmer Project Inspector, Region III  
ATTN: E. R. Schweibinz