

Duke Power Company
Nuclear Production Department
P.O. Box 33189
Charlotte, NC 28242

(704)373-4011



DUKE POWER

March 23, 1990

Division of Environmental Management
Water Quality Section
Attention: Central Files
P. O. Box 27687
Raleigh, NC 27611

Subject: Duke Power Company
NPDES Monitoring Report for
McGuire Nuclear Station - NCO024392
File: MC-702.25

Dear Sir:

In accordance with Part II, C(2) of the above referenced NPDES permit, duplicate copies of the monthly monitoring report for February, 1990 are enclosed.

The BOD for Discharge 003 exceeded the monthly average; the average was 39.0 mg/l. The incident was reported to the Mooresville Regional Office on March 6, 1990. We are reviewing the operation of the system and adjusting the retention time and the aeration patterns.

Please direct any correspondence or questions concerning the McGuire Nuclear Station NPDES Program to M. C. Griggs (704) 373-7080, Nuclear Environmental Compliance.

Very truly yours,

W.A. Haller/mdb
W. A. Haller, Manager
Nuclear Technical Services

LPH/ggb:0740

Attachments

9103270132 910323
PDR ADOCK 05000369
R PDR

TE 48

bc w/Attachments:

R. P. Michael

R. W. Eaker

D. W. Phillips

M. E. Bridges

J. S. Carter

M. C. Griggs

M.E. Kowalewski

Staff (Route)

MTI-2002.03-01

P. K. VanDoorn, Sr., NRC, MNS

D. Ebner, NRC, Atlanta, GA

NRC, Washington, D.C.