

Duke Power Company  
P.O. Box 1189  
Charlotte, NC 28222



**DUKE POWER**

July 30, 1990

Division of Environmental Management  
Water Quality Section  
Attention: Central Files  
P.O. Box 27687  
Raleigh, NC 27611

Subject: Duke Power Company  
NPDES Monitoring Report for  
McGuire Nuclear Station -- NC0024392  
File: MC-702.25

Dear Sir:

In accordance with Part II, C(2) of the above referenced NPDES permit, duplicate copies of the monthly monitoring report for June 1990 are enclosed.

Outfall 004 experienced an exceedance of the Oil and Grease limitations on June 12, 1990. The Daily Max value reported is 35mg/l and the limit is 20mg/l. At this time, it is not known what caused this excursion in Oil and Grease. However, an in-house study has been convened to determine the cause. Corrective action(s) will be implemented as soon as possible.

Please direct any correspondence or questions concerning the McGuire Nuclear Station NPDES Program to M. C. Griggs (704) 373-7080, Nuclear Environmental Compliance.

Very truly yours,

W. A. Haller, Manager  
Nuclear Technical Services

LPH/cg:0979

Enclosure

JEH  
11

bc w/Attachments: R. P. Michael  
R. W. Eaker  
D. W. Phillips  
M. E. Bridges  
J. S. Carter  
M. C. Griggs  
M.E. Kowalewski  
Staff (Route)  
MN-2002.03-01  
P.K. VanDoorn, Sr., NRC, MNS  
S.D. Ebner, NRC, Atlanta, GA  
NRC, Washington, D.C.