

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

July 8, 1983  
LOZ-83-0076

J. WILLIAMS, JR.  
SENIOR VICE PRESIDENT  
NUCLEAR OPERATIONS

Docket No. 50-358

U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Attention: Mr. J.G. Keppler  
Regional Administrator

Gentlemen:

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1  
10CFR50.55(e), ITEM M-16 ROSEMOUNT  
1151 PRESSURE TRANSMITTERS  
W.O. 57300, JOB E-5590, FILE NO. 956C,

This letter constitutes a follow-up to our final report, QA-1738, dated May 6, 1982 concerning the subject condition.

The Rosemount Model 1153 transmitter replacement program is scheduled to begin upon release of the NRC November 12, 1982 "Order to Show Cause and Order Immediately Suspending Construction" for work in this area. It is expected that installation will be completed in approximately three (3) months following release to do this work. A final report will be submitted upon completion of the corrective actions.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By *J. Williams, Jr.*  
J. WILLIAMS, JR.  
SENIOR VICE PRESIDENT

DJS/sfr

Mr. J.G. Keppler  
Regional Administrator  
July 8, 1983  
LOZ-83-0076  
Page 2

cc: NRC Office of Inspection & Enforcement  
Washington, D.C. 20555  
NRC Senior Resident Inspector  
ATTN: W.F. Christianson  
NRC Zimmer Project Inspector, Region III  
ATTN: E. R. Schweibinz