

Docket No. 50-346

License No. NPF-3

Serial No. 967

July 13, 1983



RICHARD P. CROUSE
Vice President
Nuclear
(419) 259-5221

Director of Nuclear Reactor Regulation
Attention: Mr. John F. Stolz
Operating Reactor Branch No. 4
Division of Operating Reactors
United States Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Stolz:

Under separate cover, we are transmitting three (3) original and forty (40) conformed copies of an application for Amendment to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station Unit No. 1.

This application requests that the Davis-Besse Nuclear Power Station Unit 1 Technical Specifications, Appendix A, be revised to reflect the changes attached. The proposed changes involves:

1. Section 3.4.1.2 and Bases
2. Revisions to Radiological Technical Specifications (RETS)

The attachments identifies the proposed changes and its safety evaluation and significant hazard considerations. Item 1 concerns a change to the operability requirements of the decay heat removal system in Mode 3. Item 2 concerns a revision to the RETS. The revision to a Table 4.11-1 to make the notation consistent with the Standard RETS issued by the NRC and the deletion of Ce-144 from the list of principal gamma emitters for LLD specifications. The justification for removing Ce-144 is to be added to Appendix J.

This amendment request involves one change of Class III and one revision to a previous submittal. Therefore it is determined to be a Class III request and enclosed is a check for \$4,000 as requested by 10CFR170.22.

Very truly yours,

RPC:GAB
Attachment

cc: DB-1 NRC Resident Inspector
J. W. Harris

THE TOLEDO EDISON COMPANY EDISON PLAZA 300 MADISON AVENUE TOLEDO, OHIO 43652

8307210302 830713
PDR ADOCK 05000346
P PDR

Handwritten: 11/11 w/check \$4,000