

USNRC REGION II
ATLANTA **CP&L**

83 JUL 15 P 1: 58
Carolina Power & Light Company

P. O. Box 101, New Hill, N. C. 27562
July 13, 1983

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest (Suite 2900)
Atlanta, Georgia 30303

NRC-98

50-400
5-401

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986-90 - 900,000 - UNITS 1 & 2
WELDING ON CLASS 1E 480V MOTOR CONTROL CENTERS,
PURCHASE ORDER NY-435143, ITEM 129


Dear Mr. O'Reilly:

On April 8, 1983, Mr. A. Harlin of the NRC was notified of a potentially reportable item per the provisions of 10CFR50.55(e) and 10CFR, Part 21. The Class 1E Motor Control Centers from the vendor (ITE Gould) contained weld deficiencies.

On May 6, 1983, we informed you that ITE Gould was still evaluating the welding on their motor control centers. At that time, we requested an extension until July 13, 1983 to complete our evaluation and submit a report on the reportability of this item. Since May, ITE Gould has completed their evaluation. This evaluation was received on site May 12, 1983, which stated that ITE Gould will be coming on site with revised drawings to reinspect several noted deficiencies. We will be evaluating this response and do not expect to be complete with this until August 26, 1983. For this reason, we would request an extension until August 31, 1983 for submitting a report on the reportability of this item.

Thank you for your consideration in this matter.

Yours very truly,



R. M. Parsons
Project General Manager
Shearon Harris Nuclear Power Plant

RMP/sh

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)
Mr. R. C. DeYoung (NRC)

OFFICIAL COPY

8307220145 830713
PDR ADOCK 05000400
S PDR

IE 27
110