

Georgia Power Company  
40 Inverness Center Parkway  
Post Office Box 1295  
Birmingham, Alabama 35201  
Telephone 205 877-7279

J. T. Beckham, Jr.  
Vice President - Nuclear  
Hatch Project



November 14, 1994

Docket No. 50-321

HL-4740

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Edwin I. Hatch Nuclear Plant - Unit 1  
Completion of Actions per NRC Bulletin 93-03

Gentlemen:

By letter dated May 28, 1993, the Nuclear Regulatory Commission (NRC) issued NRC Bulletin 93-03, "Resolution of Issues Related to Reactor Vessel Water Level Instrumentation in BWRS." By letter dated July 27, 1993, Georgia Power Company (GPC) provided a response to NRC Bulletin 93-03 for Plant Hatch. As part of the corrective actions for this bulletin, GPC committed to install a keepfill system on each of the affected water level instrument reference legs on each unit at the next cold shutdown beginning after July 30, 1993. By letter dated December 6, 1993, GPC informed the NRC that a keepfill system was installed on Plant Hatch Unit 2 and placed into service on November 15, 1993.

On September 22, 1994, Plant Hatch Unit 1 entered the cold shutdown condition following a planned shutdown for the purpose of refueling. During this shutdown, the Unit 1 keepfill system was installed and tested. The Unit 1 keepfill system is equivalent to the Unit 2 system described in GPC's December 6, 1993 letter and was placed in service on November 5, 1994. This completes GPC's actions associated with the NRC Bulletin 93-03.

7411220073 941114  
PDR ADOCK 05000321  
Q PDR


TE4/  
1/0

U.S. Nuclear Regulatory Commission  
November 14, 1994

Page Two

If you have any questions in this regard, please contact this office.

Sincerely,

  
J. T. Beckham, Jr.

JKB/et

cc: Georgia Power Company

Mr. H. L. Sumner, Nuclear Plant General Manager  
NORMS

U.S. Nuclear Regulatory Commission, Washington, D.C.

Mr. K. Jabbour, Licensing Project Manager

U.S. Nuclear Regulatory Commission, Region II

Mr. S. D. Ebnetter, Regional Administrator

Mr. B. L. Holbrook, Senior Resident Inspector - Hatch