

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 ALJIMF1200-000000-0034111145
7 8 9 14 15 25 26 30 37 38

CON'T

01 REPORT SOURCE L605000348706168380715839
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 1035 on 6/16/83 during unit startup operations, pressurizer pressure dropped to

03 2205 PSIA. Tech. Spec. 3.2.5, in part, requires pressurizer pressure to be greater

04 than or equal to 2220 PSIA. Tech. Spec. 3.2.5 action statement requirements were

05 met. Health/Safety of the public was not affected.

06

07

08

09 SYSTEM CAUSE CAUSE COMPONENT COMP. VALVE
CODE CODE SUBCODE CODE SUBCODE SUBCODE
C B 11 A 12 A 13 Z Z Z Z Z Z 14 Z 15 Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LER/NO REPORT NUMBER 83
21 22
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
ACTION FUTURE EFFECT SHUTDOWN SEQUENTIAL OCCURRENCE REPORT REVISION
TAKEN ACTION ON PLANT METHOD REPORT NO. CODE TYPE NO.
H 18 Z 19 Z 20 Z 21 000000 03 03 L 0
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 This event was due to personnel error. A RCS boratation combined with a load

11 increase resulted in the drop in pressurizer pressure. The pressurizer pressure

12 was restored to greater than 2220 PSIA at 1040 on 6/16/83. The individuals

13 involved were counseled concerning this incident.

14

15 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
C 28 015 29 NA A 31 Operational Event
7 8 9 10 11 12 13 14 15 16 17 18 19 20

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
000 37 Z 38 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20

18 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
000 40 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
Z 42 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20

20 PUBLICITY ISSUED DESCRIPTION (45)
N 44 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20

NAME OF PREPARER

W. G. Hairston, III

PHONE:

(205) 899-5156

8307220320 830715
PDR ADOCK 05000348
S PDR