



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

July 8, 1983

JAMES P. MCGAUGHY, JR.  
VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Special Report 83-051/0 - PGCC  
Fire Protection Systems  
Removed From Service  
AECM-83/0378

Beginning on May 26, 1983, PGCC Halon fire protection systems were removed from service as needed to correct differences between the design documents and the as-built configuration. An LCO was entered in accordance with Technical Specification 3.7.6.4.

All identified differences and the corrective actions will be identified on Material Non-Conformance Report 423-83. All hardware modifications have been completed and retested satisfactorily. The LCO will be lifted when the work package is closed. This is submitted as a Special Report as the LCO time limit of 14 (fourteen) days was exceeded.

Yours truly,

*J.P. McGaughy*  
for J. P. McGaughy

JPM:sap

cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555  
Member Middle South Utilities System

8307220482 830708  
PDR ADOCK 05000414  
PDR  
S

ORIGINAL COPY

IE22  
1/0

USNRC REGION II  
ATLANTA, GEORGIA  
JUL 18 1983  
P1:28