

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER, DALLAS, TEXAS 75201-3050

Log # TXX-4010

File # 905.4

July 19, 1983

Mr. B. J. Youngblood
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
D4/D5 STEAM GENERATOR MODIFICATIONS
ADDITIONAL INFORMATION

Dear Mr. Youngblood:

The following additional information addresses items of concern voiced by the NRC regarding the CPSES FSAR submittal describing the D4/D5 Steam Generator Tube Vibration Fix.

Item 1. Accident Analysis Statement

The existing CPSES Chapter 15 accident analyses envelope all changes in parameters resulting from the Steam Generator Tube Vibration Fix.

Item 2. Quality Assurance Statement

CPSES applies 10 CFR 50 Appendix B, quality assurance to the steam generator modifications. All field work is performed in accordance with the appropriate sections of Westinghouse WCAP-8370 Rev. 9A and Addendum #1 "WRD Quality Assurance Plan", Westinghouse NSID, "Quality Assurance Program Plan" WCAP-9245 Rev. 6, and pertinent CPSES quality assurance requirements. Eddy current testing complies with the procedures established by the ASME Code, Section XI, "In-service Inspection", and Regulatory Guide 1.83, "In-service Inspection of Pressurized Water Reactor Steam Generator Tubes", for the selection of tubes to be tested and the frequency of testing.

Should you have additional questions, please contact me.

Sincerely,

H. C. Schmidt
H. C. Schmidt

BSD:tlb

8307250370 830719
PDR ADOCK 05000445
A PDR

8001
1/0