

USNRC RE  
ATLANTA, GEORGIA

CP&L

Carolina Power & Light Company

83 JUL 19 10:28  
P. O. Box 101, New Hill, North Carolina 27562  
July 14, 1983

FILE: SH N-2/18  
Item 137

MQAH 83-174

Mr. James P. O'Reilly  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Northwest  
Atlanta, Georgia 30303

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1  
DOCKET NO. 50-400  
SA-36 HANGER MATERIAL RECEIVED IN LIEU OF SA-564 TYPE 630

Dear Mr. O'Reilly:


This is to confirm the July 14, 1983 telephone conversation between Mr. N. J. Chiangi and Mr. A. Hardin. Mr. Hardin was informed that the June 14, 1983 potentially reportable item, pertaining to Seismic Class I, SA-36, carbon steel pipe hanger material manufactured by Bergen-Paterson that was supplied in lieu of the ordered SA-564 type 630 stainless steel material (CP&L purchase order specified SA-564 type 630 material, but listed carbon steel (SA-36) catalog part numbers), has been evaluated and considered not to be reportable per the provisions of 10CFR50.55(e) and 10CFR Part 21.

Thank you for your consideration in this matter.

Yours very truly,

NJC/mt

cc: Mr. R. C. DeYoung  
Mr. G. Maxwell  
Mr. R. L. Prevatte

  
N. J. Chiangi - Manager  
Quality Assurance/Quality Control  
Harris Plant

OFFICIAL COPY

IE 27

1/0

8307250399 830714  
PDR ADOCK 05000400  
S PDR