



LOUISIANA
POWER & LIGHT


142 DELARONDE STREET
P. O. BOX 6008 • NEW ORLEANS, LOUISIANA 70174 • (504) 366-2345

July 15, 1983

W3I83-0237

Q-3-A35.07.81

Mr. John T. Collins, Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76012



SUBJECT: Waterford SES Unit No. 3
Docket No. 50-382
Significant Construction Deficiency No. 81
"Shelf Life Exceeded on Cable Splice
and Termination Tape"
Second Interim Report

REFERENCE: LP&L letter W3I83-0189 dated May 24, 1983

Dear Mr. Collins:

The above referenced letter indicated submittal of a Final Report to the USNRC no later than July 22, 1983.

At the present time, dielectric testing of medium and low voltage terminations and splices by Okonite is ongoing and is expected to be completed by July 30, 1983. Results of this testing will be evaluated for acceptability.

A Final Report will therefore be submitted to the USNRC by August 30, 1983.

Very truly yours,

Thomas F. Drummond for

F. J. Drummond
Project Support Manager - Nuclear

FJD/RWP/MAL:keh

cc: 1) Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

3) Mr. E. L. Blake

2) Director
Office of Management
Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

4) Mr. W. M. Stevenson