

Omaha Public Power District
1623 Harney Omaha, Nebraska 68102
402/536-4000

July 22, 1983
LIC-83-174

Mr. Robert A. Clark, Chief
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Division of Licensing
Operating Reactors Branch No. 3
Washington, D.C. 20555

References: (1) Docket No. 50-285
(2) Letter dated March 8, 1983 from W. C. Jones to R. A. Clark (LIC-83-054)
(3) Letter dated March 14, 1983 from R. A. Clark to W. C. Jones

Dear Mr. Clark:

NUREG-0737, Items II.F.1.6
and III.D.3.4

The above referenced letters included communications regarding the District's completion of NUREG-0737, Items II.F.1.6 (containment hydrogen monitors) and III.D.3.4 (control room habitability including instrumentation for detection of airborne iodine radiation in the control room, electrical and mechanical modifications to the HVAC, and instrumentation for monitoring of toxic chemical gases). Completion schedules for these items were also included in the above referenced correspondence.

The purpose of this letter is to provide confirmation that the following actions have been completed. The repairs referenced in the March 14, 1983 letter for Item II.F.1.6 (containment hydrogen monitors) have been completed. Installation of the instrumentation for the detection of airborne iodine radiation in the control room was completed in accordance with the schedule given in reference (2). It has been determined that no modifications are required for the electrical and mechanical portions of the control room heating and ventilation system and, therefore, this item is considered completed. As indicated in the March 8, 1983


8307260143 830722
PDR ADOCK 05000285
P PDR

A046
1/0

Mr. Robert A. Clark
LIC-83-174
Page Two

letter, the installation of instrumentation for monitoring toxic chemical gases in the control room is presently scheduled to be completed by June 30, 1984.

Sincerely,



W. C. Jones
Division Manager
Production Operations

WCJ/KJM:jmm

cc: LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, N.W.
Washington, D.C. 20036

Mr. L. A. Yandell, Senior Resident
Inspector