



**LOUISIANA**  
**POWER & LIGHT**

142 DELARONDE STREET  
NEW ORLEANS, LOUISIANA

• P.O. BOX 8008  
70174-8008

• (504) 386-2345

July 21, 1983

W3P83-1223

Q-3-A29.20

Director of Nuclear Reactor Regulation  
Attention: Mr. G. W. Knighton, Chief  
Licensing Branch Number 3  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: Waterford 3 SES  
Docket No. 50-382  
SER Issues - Monitoring NPIS Settlement

Dear Sir:

As part of our effort in closing-out SER issues, we have identified the following issue which we believe has been resolved, yet has not been closed-out in the SER:

Monitoring NPIS Settlement (License Condition) - Procedure PE-TEM-002 has been written to require that settlement of the Nuclear Plant Island Structure (NPIS) be monitored annually for a period of at least three years.

It is our understanding that the implementation of this procedure will satisfy the NRC's concerns, and as such we request that an SER supplement be written to remove this License Condition.

If you have any questions regarding this matter, please feel free to contact Roy Prados at (504) 363-8773.

Yours very truly,

F. J. Drummond  
Project Support Manager-Nuclear

FJD/RMF/ssd

cc: E. L. Blake, W. M. Stevenson, J. Wilson (NRC), L. Constable

8307260511 830721  
PDR ADOCK 05000382  
F PDR

Boo!  
1/0