

**LICENSEE EVENT REPORT**

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N		Y	R	E	G	1	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5																																																				
8		9										14										15										25										26										30										57										58									
		LICENSEE CODE																				LICENSE NUMBER																				LICENSE TYPE																				CAT																			

CON'T

C	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	2	4	4	7	0	6	2	1	8	3	8	0	7	2	0	8	3	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While the reactor was in a hot shutdown mode of operation a calibration check of

0 3 | steam generator steam flow transmitter FT-464 found the transmitter out of tolerance

G 4 | low approx. 1 1/2%. This transmitter provides signals for the reactor protection

0 5 | logic (low S/G level + FW SF) and steam line isolation safeguard logic (Hi S.F. +

0 6 | low Tavg + S.I., or Hi-Hi S.F. + S.I.). This is a violation of Tech. Spec. 3.5.3.

0 7 |

0	8
7	8

SYSTEM CODE I B 11		CAUSE CODE E 12		CAUSE SUBCODE E 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE T 15		VALVE SUBCODE Z 16							
LER/RO REPORT NUMBER 17		EVENT YEAR 8 3 21 22		SEQUENTIAL REPORT NO. 0 2 4 23 24 25 26		OCCURRENCE CODE 0 3 27 28 29		REPORT TYPE L 30		REVISION NO. 0 31 32							
ACTION TAKEN E 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22 37 38 39 40		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. N 24		PRIME COMP. SUPPLIER L 25		COMPONENT MANUFACTURER F 1 8 0 26 44 45 46 47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The transmitter error was attributed to a pressure static shift. The transmitter

1 1 was adjusted and returned to service. The transmitter is a Foxboro model N-E11DM.

1 2

1 3

1 4

FACILITY STATUS (1) 5 (2) G (28) % POWER (3) 0 (4) 0 (5) 0 (29) OTHER STATUS (30) N/A  
 METHOD OF DISCOVERY (31) C (32) Calibration Check  
 ACTIVITY CONTENT RELEASED OF RELEASE (33) Z (34) Z (35) N/A  
 LOCATION OF RELEASE (36) N/A

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	37	Z	37	N/A	IERZ

PERSONNEL INJURIES		DESCRIPTION
NUMBER		
1 8	0 0 C	40 N/A

1	9	Z	42	N/A	8308010352 830720 PDR ADDCK 05000244 S PDR
---	---	---	----	-----	--

8 9 10  
PUBLCITY  
ISSUED DESCRIPTION (45)  
2 0 N (44) . N/A  
NRC USE ONLY

NRC USE ONLY

7 8 9 10 68 69 80  
NAME OF ORG. E. Clair Edgar PHONE 315-524-4446 ext 248

NAME OF OPERATOR E. Clair Edgar

PHONE. 315-524-4446 ext 248



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

JOHN E. MAIER  
Vice President

TELEPHONE  
AREA CODE 716 546-2700

July 20, 1983

Dr. Thomas E. Murley, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, PA 19406

Subject: LER 83-024/03L, Steam Generator Flow Transmitter found  
out of tolerance.  
R. E. Ginna Nuclear Power Plant, Unit No. 1  
Docket No. 50-244

Dear Dr. Murley:

In accordance with Technical Specifications, article 6.9.2.b.1,  
"Reactor protection system or engineered safety feature instrument  
settings which are found to be less conservative than those  
established by the technical specifications but which do not  
prevent the fulfillment of the functional requirements of affected  
systems", the attached Licensee Event Report LER 83-024/03L-0  
is hereby submitted.

Very Truly Yours,

*John E. Maier*  
John E. Maier

Attachment

xc: Document Control Desk (1)

IE 22  
11