



GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

June 11, 1991
C321-91-2163

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555


Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Monthly Operating Report

In accordance with the Oyster Creek Nuclear Generating Station Operating License No. DPR-16, Appendix A, Section 6.9.1.C, enclosed are two (2) copies of the Monthly Operating Data (gray book information) for the Oyster Creek Nuclear Generating Station.

If you should have any questions, please contact Brenda DeMerchant, Oyster Creek Licensing Engineer at (609) 971-4642.

Sincerely,



J.J. Barton
Vice President and Director
Oyster Creek

JJB/BDEM: jc
Enclosures

cc: Administrator, Region 1
Senior NRC Resident Inspector
Oyster Creek NRC Project Manager

(MOR)

9106190066 910531
PDR ADOCK 05000219
R PDR

TE24
11

MONTHLY OPERATING REPORT - MAY 1991

During May, Oyster Creek continued the 13R refueling outage.

MONTHLY OPERATING REPORT MAY 1991

The following Licensee Event Reports were submitted during the month of May, 1991:

None

AVERAGE DAILY POWER LEVEL
NET MWe

DOCKET # 50219
UNIT OYSTER CREEK #1
REPORT DATE JUNE 7, 1991
COMPILED BY JOHN H. SEDAR
TELEPHONE # 609-971-4698

MONTH: MAY, 1991

<u>DAY</u>	<u>MW</u>	<u>DAY</u>	<u>MW</u>
1.	0	16.	0
2.	0	17.	0
3.	0	18.	0
4.	0	19.	0
5.	0	20.	0
6.	0	21.	0
7.	0	22.	0
8.	0	23.	0
9.	0	24.	0
10.	0	25.	0
11.	0	26.	0
12.	0	27.	0
13.	0	28.	0
14.	0	29.	0
15.	0	30.	0
		31.	0

REFUELING INFORMATION - MAY, 1991

Name of Facility: Oyster Creek Station #1

Scheduled date for next refueling shutdown: November 27, 1992

Scheduled date for restart following refueling: June 18, 1991

Will refueling or resumption of operation thereafter require a Technical Specification change or other license amendment?

Yes

Technical Specification Change Request 180 was submitted to the NRC on 5-07-90. This submittal was made in accordance with GL 88-16 to incorporate cycle specific parameters in a core operating limits report.

Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:

1. General Electric Fuel Assemblies - Fuel design and performance analysis methods have been approved by the NRC.
2. Exxon Fuel Assemblies - No major changes have been made nor are there any anticipated.

The number of fuel assemblies	(a) in the core	=	560
	(b) in the spent fuel storage pool	=	1708
	(c) in dry storage	=	44

The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies:

Present Licensed Capacity: 2600

The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity:

The reracking of the fuel pool is now complete. All ten (10) racks are now installed. Discharge capacity to the spent fuel pool will be available through the 1994 refueling outage.

OPERATING DATA REPORT
OPERATING STATUS

1. DOCKET: 50-219
2. REPORTING PERIOD: 5/91
3. UTILITY CONTACT: JOHN SEDAR (609)971-4698
4. LICENSED THERMAL POWER (MWt): 1930
5. NAMEPLATE RATING (GROSS MWe): $687.5 \times 0.8 = 550$
6. DESIGN ELECTRICAL RATING (NET MWe): 650
7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 642
8. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 620
9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS:

NONE

10. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWe):

NONE

11. REASON FOR RESTRICTION, IF ANY:

NONE

	<u>MONTH</u>	<u>YEAR</u>	<u>CUMULATIVE</u>
12. REPORT PERIOD HOURS	744.0	3623.0	187919.0
13. HOURS RX CRITICAL	0.0	1111.0	120176.2
14. RX RESERVE SHUTDOWN HRS	0.0	0.0	918.2
15. HRS GENERATOR ON-LINE	0.0	1109.2	117022.2
16. UT RESERVE SHUTDOWN HRS	0.0	0.0	1208.6
17. GROSS THERM ENERGY (MWH)	0	2099088	196994044
18. GROSS ELEC ENERGY (MWH)	0	707030	66312953
19. NET ELEC ENERGY (MWH)	-3324	670098	63630130
20. UT SERVICE FACTOR	0.0	30.6	62.3
21. UT AVAIL FACTOR	0.0	30.6	62.9
22. UT CAP FACTOR (MDC NET)	0.0	29.8	54.6
23. UT CAP FACTOR (DER NET)	0.0	28.5	52.1
24. UT FORCED OUTAGE RATE	0.0	0.0	11.5
25. FORCED OUTAGE HRS	0.0	0.0	15270.0

26. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, DURATION):

CURRENTLY SHUT DOWN FOR CYCLE 13 REFUELING OUTAGE.

27. IF CURRENTLY SHUTDOWN, ESTIMATED STARTUP DATE:

JUNE 18, 1991

UNIT SHUTDOWN3 AND POWER REDUCTIONS

DOCKET NO. 50-219
 UNIT NAME Oyster Creek
 DATE May, 1991
 COMPLETED BY T. Corcoran
 TELEPHONE 971-4986

REPORT MONTH May, 1991

NO.	DATE	TYPE F: Forced S: Scheduled	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
104	910216	S	744	C	1	Shutdown for 13R Refueling Outage

Summary :

(1) REASON

- a. Equipment Failure (Explain)
- b. Maintenance or Test
- c. Refueling
- d. Regulatory Restriction

- e. Operator Training License Exam
- f. Administrative
- g. Operational Error (Explain)
- h. Other (Explain)

(2) METHOD

- 1. Manual
- 2. Manual Scram
- 3. Automatic Scram
- 4. Other (Explain)