

Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

July 18, 1983  
ANPP-27333-RQT/BSK

RECEIVED  
NRC

1983 JUL 25 PM 12:55

REGION V

U. S. Nuclear Regulatory Commission  
Region V  
Creskide Oaks Office Park  
1450 Maria Lane - Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. D. M. Sternberg, Chief  
Reactor Projects Branch 1

Subject: Time Extension for Report - DER 83-09  
A 50.55(e) Potentially Reportable Deficiency Relating to Unit 1  
LPSI Pump "A" Suction Strainer Contains Foreign Material, And  
Pump "B" Strainer is Torn.  
File: 83-019-026, D.4.33.2

Reference: (A) Telephone Conversation Between T. Young and G. Duckworth  
on February 16, 1983.  
(B) ANPP-23238 dated March 14, 1983 (Interim Report)


Dear Sir:

The NRC was notified of a Potentially Reportable Deficiency in Reference (A), and an Interim Report was transmitted by Reference (B). At that time, it was estimated that a Final Report would be available by July 15, 1983.

Due to the extensive investigation and evaluation required, it is now expected that this information will be finalized by September 21, 1983, at which time a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,



E. E. Van Brun, Jr.  
APS Vice President  
Nuclear Projects Management  
ANPP Project Director

EEVBJr/RQT:ru

cc: See Page 2

8308030108 830718  
PDR ADOCK 05000528  
S PDR

11 IE27

U. S. Nuclear Regulatory Commission  
Page 2

cc: Richard DeYoung, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

T. G. Woods, Jr.  
G. C. Andognini  
J. A. Roedel  
D. B. Fasnacht  
A. C. Rogers  
B. S. Kaplan  
W. E. Ide  
J. Vorees  
J. R. Bynum  
P. P. Klute/D. D. Green  
A. C. Gehr  
W. J. Stubblefield  
W. G. Bingham  
R. L. Patterson  
R. W. Welcher  
R. M. Grant  
D. R. Hawkinson  
L. E. Vorderbrueggen  
G. A. Fiorelli  
S. R. Frost

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339