

# Illinois Power Company

U-0655  
0920-L  
L30-83(07-27)-L

500 SOUTH 27TH STREET, P. O. BOX 511, DECATUR, ILLINOIS 62525-1805  
July 27, 1983

Docket No. 50-461

Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Subject: Clinton Power Station Unit 1  
Application of ASME Code Case N-315


Dear Mr. Schwencer:

Illinois Power Company intends to make use of ASME Code Case N-315, "Repair of Bellows", approved February 14, 1983, on ten guard pipe expansion bellows. These expansion bellows serve as a flexible boundary connecting the various guard pipes to their respective drywell penetration sleeves.

We request NRC approval for use of ASME Code Case N-315 at the Clinton Power Station for the purpose of making the necessary repairs on our expansion bellows.

Please advise us as soon as possible if you have any questions on our request to use this code case.

Sincerely,



G. E. Wuller  
Supervisor - Licensing  
Nuclear Station Engineering

DAP/em/LET1

cc: Dr. H. Abelson, NRC Clinton Licensing Project Manager  
Mr. H. H. Livermore, NRC Senior Resident Inspector  
Illinois Department of Nuclear Safety

8308030119 830727  
PDR ADOCK 05000461  
A PDR

Boo1  
1/0