

LICENSEE EVENT REPORT

Updated Report
Previous Report Dated 5/31/83

CONTROL BLOCK:

--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7	0	1	8	9	I	L	D	R	S	3	14	15	2	0	0	-	0	0	0	0	0	-	0	0	25	26	3	4	1	1	1	1	30	37	4			58	5
				LICENSEE CODE										LICENSE NUMBER										LICENSE TYPE										CAT					

CON'T

REPORT SOURCE L 6 0 5 0 0 0 2 4 9 7 0 5 0 2 8 3 3 0 7 1 5 8 3 9

60 61 DOCKET NUMBER 68 69 70 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operations torus water level was lowered by pumping to the hotwell
03 via LPCI system. LPCI core spray pump pressure alarm annunciated and cleared after
04 a close signal was given to core spray valve MO 1402-25A. After closing the valve
05 indicating lights and breaker tripped. There was no effect on public health or
06 safety. The event is of minimum safety significance since the breaker reset and
07 valve was cycled satisfactorily. Last occurrence reported by 050-237/73-82.
08

09		SYSTEM CODE		SF		CAUSE CODE		D		CAUSE SUBCODE		Z		COMPONENT CODE				CKTBRK		COMP. SUBCODE		A		VALVE SUBCODE		Z	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34
LER RD REPORT NUMBER		EVENT YEAR		—		SEQUENTIAL REPORT NO.		018		—		OCCURRENCE CODE		03		REPORT TYPE		X		—		REVISION NO.		1			
35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		Z		HOURS		0000		ATTACHMENT SUBMITTED		N		NPRD-4 FORM SUB.		Y		PRIME COMP. SUPPLIER		N		COMPONENT MANUFACTURER	
63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90
E		G		Z		Z		0		0		0		0		N		Y		N		G		0		8	
91	92	93	94	95	96	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	112	113	114	115	116	117	118

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Cause was due to procedural inadequacy. The breaker was incorrectly set at (2)

1 1 two instead of (5) five. An incorrect breaker data sheet was used which was not

1 2 controlled by station procedure. The breaker was set at (5) and the valve cycled

1 3 from the control room. A corrected breaker data sheet is being added to a station

1 4 procedure.

1		5		E		28		0		9		8		29		N/A		30		METHOD OF DISCOVERY		A		31		DISCOVERY DESCRIPTION		32		Operator Observation		33	
---	--	---	--	---	--	----	--	---	--	---	--	---	--	----	--	-----	--	----	--	---------------------	--	---	--	----	--	-----------------------	--	----	--	----------------------	--	----	--

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)
1 6 7 8 9 Z (33) 10 Z (34) 11 N/A 44
LOCATION OF RELEASE (36)
45 N/A 30

PERSONNEL EXPOSURES

NUMBER		TYPE	DESCRIPTION
1	7	000	N/A

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
000	N/A

1		9		Z		42		N/A		8308040298 830715 PDR ADOCK 05000249 S PDR	
---	--	---	--	---	--	----	--	-----	--	--	--

[illegible]

NAME OF PREPARER L. Coyle

PHONE: (815) 942-2920 x526

SUPPLEMENT TO DVR

DVR NO.	STA	UNIT.	YEAR	NO.
D -	12	- 3	- 83	- 32

PART 1	TITLE OF EVENT	OCCURRED	
	Core Spray Injection Valve 3-1402-25A	5/2/83 DATE	0700 TIME
REASON FOR SUPPLEMENTAL REPORT			
Clarify cause description			
PART 2			
ACCEPTANCE BY STATION REVIEW	<u>J. Brunner</u>	<u>J. A. Custer</u>	
DATE	<u>7/18/83</u>	<u>7/20/83</u>	
SUPPLEMENTAL REPORT APPROVED AND AUTHORIZED FOR DISTRIBUTION	<u>R. M. Pagan</u>		<u>7/20/83</u>
	STATION SUPERINTENDENT		DATE



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

DmB

July 14, 1983

DJS Ltr #83-697

James G. Keppler, Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Update to Reportable Occurrence Report #83-18/03X-1, Docket #050-249 is being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2.(b), conditions leading to operation in a degraded mode permitted by a limiting condition for operation or plant shutdown required by a limiting condition for operation. Updated report is being submitted to clarify cause description.

D.J. Scott
Station Superintendent
Dresden Nuclear Power Station

DJS/kjl

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
U.S. NRC, Document Management Branch
File/NRC

JUL 25 1983

11 IE 22