

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I D C C 1 200-000000-000 341111 4 5
7 8 9 14 15 25 26 30 57 CAT 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T
01 1 605000315 7062483 8072083 9
7 8 60 61 68 69 74 75 80
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 DURING NORMAL PLANT OPERATION, A SECURITY OFFICER FOUND THE CO₂ SWITCH FOR THE
03 UNIT 1 CD DIESEL GENERATOR ROOM IN THE ISOLATE POSITION WITH NO ONE IN THE ROOM.
04 THIS IS NON-CONSERVATIVE WITH RESPECT TO THE REQUIREMENTS OF T.S.3.7.9.3. THE
05 CONDITION EXISTED FOR TWELVE (12) MINUTES. THE FIRE DETECTION SYSTEM WAS OPERABLE
06 DURING THIS PERIOD. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS OCCUR-
07 RENCES WERE REPORTED VIA RO NOS. (UNIT 2):316/82-054,062,074,076,084,83-022,028&034.
08 AND (UNIT 1):315/82-037,044,045,049,068,081,082,108&83-048.
7 8 9 80

09 A B 11 A 12 X 13 Z Z Z Z Z Z 14 Z 15 Z 16
7 8 9 10 11 12 13 18 19 20
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE

17 83 060 03 L 0
7 8 21 22 24 26 27 28 29 30 31 32
LER-RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

H 18 Z 19 Z 20 Z 21 0000 22 N 23 N 24 Z 25 Z 9 9 9 26
33 34 35 36 37 40 41 42 43 44 47
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPR-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 THE PRIMARY CAUSE OF THE EVENT WAS A PERSONNEL ERROR. A CONTRACTOR CRAFT EMPLOYEE
11 EXITED THE AREA WITHOUT RETURNING CO₂ SYSTEM TO NORMAL, FOR OPERATION. TO INCREASE
12 AWARENESS OF THE FIRE PROTECTION SYSTEM REQUIREMENTS, A PERSONAL CONFERENCE AND A
13 REVIEW OF THE INDIVIDUALS RESPONSIBILITY REGARDING FIRE PROTECTION SYSTEMS WERE
14 HELD.
7 8 9 20

15 E 28 100 29 N/A B 31 SECURITY OFFICER OBSERVATION
7 8 9 10 11 12 13 44 45 46 80
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

16 Z 33 Z 34 N/A N/A 36
7 8 9 10 11 12 44 45 80
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

17 000 37 Z 38 N/A
7 8 9 10 11 12 13 80
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

18 000 40 N/A
7 8 9 10 11 12 80
PERSONNEL INJURIES NUMBER DESCRIPTION

19 Z 42 N/A
7 8 9 10 80
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

20 N 44 N/A
7 8 9 10 80
ISSUED PUBLICITY DESCRIPTION

8308040364 830720
PDR ADOCK 05000315
S PDR

NRC USE ONLY
68 69 80
(616) 465-5901

NAME OF PREPARER L. W. CASTLE PHONE (616) 465-5901