

APPROVED BY OMB
3150-0011
EXPIRES 4-30-82

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	D	C	C	N	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	9					14		15										25		26						30		37	CAT: 58
LICENSR CODE		LICENSR NUM		LICENSR TYPE		CAT																								

CON'T

REPORT SOURCE: 01 L 6 0 5 0 0 0 3 1 8 7 0 6 2 2 8 3 8 0 7 2 1 8 3 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 0835 during preventive maintenance inspection, the containment atmos-
0 3 | phere particulate radioactivity monitoring system filter paper was
0 4 | discovered to be torn and wrinkled, rendering the monitor inoperable
0 5 | (T.S. 3.4.6.1). The filter paper was replaced and at 1805 the monitor
0 6 | was returned to service. The containment atmosphere gaseous monitoring
0 7 | system and sump level alarm system remained operable throughout the
0 8 | event. Similar events: none.

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE					
0	9	B	B	B	A	Z	Z	Z	Z	Z	Z	Z	Z				
7	8	9	10	11	12	13	14	15	16	17	18	19	20				
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
17	8	3	—	0	3	4	/	0	3	L	—	0					
21	22	23	24	25	26	27	28	29	30	31	32						
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
A	F	Z	Z	0	0	0	0	N	N	Z	Z	9	9	9	9		
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Normal air sample moisture and air flow caused the filter paper to tear.

1 1 A modification to support the back of the filter paper to prevent tear-

1 2 ing has been completed on Unit 1. The change has thus far proven effec-

1 3 tive and will be incorporated in the Unit 2 system. No further action is

1 4 deemed necessary at this time.

1 5 E 28 1 0 0 29 N/A 30 B 31 Preventive Maintenance 32

ACTIVITY CONTENT RELEASED OF RELEASE (35) LOCATION OF RELEASE (36)

1 6 2 33 34 N/A N/A

PERSONNEL EXPOSURES									
NUMBER		TYPE		DESCRIPTION (39)					
1	7	0	0	0	(37)	Z	(38)	N/A	

PERSONNEL INJURIES		DESCRIPTION		(41)
NUMBER				
1	8	0	0	0
		(40)		N/A

7 8 9 11 12
LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION (43)
8308090679 830721
PDR ADOCK 05000318
PDR

1 9 Z (42) N/A S

PUBLICITY
ISSUE/ DESCRIPTION (45) NRC USE ONLY

20 N 44 N/A

NAME OF PREPARER P. A. Pieringer/L. F. Basso

PHONE: 301-269-4742/4933

NRC USE ONLY

7E22

BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

July 21, 1983

Dr. Thomas E. Murley
Regional Administrator
U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406


Docket No. 50-318
License No. DPR 69

Dear Dr. Murley:

Attached is LER 83-34/3L, as required by Technical Specification 6.9.

Should you have any questions regarding this report, we would be pleased to discuss them with you.

Very truly yours,


for L. B. Russell
Plant Superintendent

LBR:LFB:bsb

cc. Director, Office of Management Information
and Program Control
Messrs: A. E. Lundvall, Jr.
J. A. Tiernan

IE 22
11