



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

July 29, 1983

USNRC REGION II
ATLANTA, GEORGIA
83 AUG 9 9:17

NUCLEAR PRODUCTION DEPARTMENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-061/0 - Fire
Rated Penetrations Opened
to Implement Design Change
Packages
AECM-83/0430

Beginning on July 1, 1983, the fire rated penetrations listed on the attached page were opened to implement design change packages. Hourly fire watches were established within 1 (one) hour and will be maintained for the duration of the planned maintenance activities in accordance with Technical Specification 3.7.7. This is reported as a Special Report pursuant to Technical Specification 6.9.2.

This condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. The work tasks are expected to be complete by September 10, 1983.

Yours truly,

L. F. Dale
Manager of Nuclear Services

EBS/SHH:sap
Attachment

cc: (See Next Page)

8308110114 830729
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY
IE 22
11

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0430

Page 2

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Beginning on July 1, 1983, the following fire rated penetrations were opened to implement design change packages:

| <u>DUCT COVERS</u> | <u>INCIDENT REPORT #</u> |
|----------------------|--------------------------|
| L046/LA18 | 83-07-03 |
| <u>FIRE BARRIERS</u> | |
| L046/LA18 | 83-07-03 |
| L046/LA19 | 83-07-03 |
| L045/LA19 | 83-07-03 |
| LA1/L086 | 83-07-02 |
| LA4/L087 | 83-07-02 |
| LA4/L089 | 83-07-02 |
| LA4/L091 | 83-07-02 |
| LA14/L092 | 83-07-02 |
| LA57/L064 (U710) | 83-07-05 |
| LA45/L064 (U710) | 83-07-05 |
| L084/LA36 (U733) | 83-07-24 |
| L084/LA43 (U733) | 83-07-24 |