



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

August 2, 1983

USNRC REGION II  
ATLANTA, GEORGIA  
83 AUG 8 9:17

## NUCLEAR PRODUCTION DEPARTMENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station

Unit 1

Docket No. 50-416

License No. NPF-13

File 0260/L-835.0

Special Report 83-064/0 -- Fire

Door Blocked Open to

Support Planned Work

Activity

AECM-83/0438

On June 26, 1983, fire door 1A413 to stairwell 1A12 on elevation 166 feet of the Auxiliary Building was blocked open to support a planned work activity. A fire watch was established at the start of the planned maintenance activity and will be maintained for the duration in accordance with Technical Specification 3.7.7.

The door was not closed by the seven day time limit of the action statement, therefore, this is being submitted as a Special Report pursuant to Technical Specification 6.9.2. This condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. The planned maintenance activity is expected to be completed by September 12, 1983.

Yours truly,

L. F. Dale

Manager of Nuclear Services

EBS/SHH:sap

cc: (See Next Page)

8308110126 830802  
PDR ADOCK 03000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY  
IE 22  
110

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0438

Page 2

cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555