



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

JOHN E. MAIER  
Vice President

TELEPHONE  
AREA CODE 716 546-2700

May 6, 1983

Mr. George H. Smith, Director  
Division of Emergency Preparedness and Operational Support  
U. S. Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Subject: Emergency Preparedness Appraisal 50-244/81-22  
R. E. Ginna Nuclear Power Plant, Unit No. 1  
Docket No. 50-244

Dear Mr. Smith:

This letter responds to several open items from NRC Emergency Preparedness Appraisal 50-244/81-22 which was transmitted to us by letter dated May 20, 1982.

Enclosed is a copy of Nuclear Production Administrative Procedure #4, titled "Functions and Duties of Corporate Emergency Planner." This procedure completes our actions on Items A-1, B-1 and B-2 of your inspection and our response as outlined in my letter to you of June 30, 1982.

Due to manpower limitations, Item A-9 "A study on the transfer, sampling, storage and analysis of highly radioactive liquid waste" was not completed by March 30, 1983 as committed in our June 30, 1982 letter. This study will be completed by December 30, 1983.

Evaluation of an alternate evacuation assembly area, Item A-20, is continuing and will be completed by September 30, 1983.

In response to Item B-3, a constant air monitor has been ordered for placement in the control room. This will complete this item since completion of control room ventilation modification is not necessary to resolve this item. This unit will be in place and operational by June 30, 1983.

Item B-6, Post Accident Sampling System should be operational by June 30, 1983 or three weeks after achieving criticality following the Spring 1983 Refueling Outage, whichever is later, in accordance with NRC confirmatory order of March 14, 1983.

8308120150 830808  
PDR ADOCK 05000244  
Q PDR


DATE May 6, 1983

TO Mr. George H. Smith, Director

A study to determine the need for additional Area Radiation Monitors in the Plant has been completed and a draft report is currently being reviewed. (Item B-7)

An SC procedures sub-committee to PORC has been established to review the SC radiation emergency procedures and emergency supplies. They will evaluate what corrective action equipment and supplies should be kept accessible for use during emergencies. A report will be completed by December 31, 1983. (Item B-28)

Very truly yours,

  
John E. Maier