


VERMONT YANKEE NUCLEAR POWER CORPORATION



RD 5, Box 169, Ferry Road, Brattleboro, VT 05301

Proposed Change No. 108
Supplement I

2.C.2.1
FVY 83-89

REPLY TO:

ENGINEERING OFFICE

1671 WORCESTER ROAD
FRAMINGHAM, MASSACHUSETTS 01701
TELEPHONE 617-872-8100

August 4, 1983

United States Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Office of Nuclear Reactor Regulation
Mr. D. G. Eisenhut, Director
Division of Licensing

References: (a) License No. DPR-28 (Docket No. 50-271)
(b) Letter, VYNPC to USNRC, FVY 83-41, Proposed Change No. 108
to the Vermont Yankee Technical Specifications, dated
May 20, 1982

Subject: Safety-Related Shock Suppressors (Snubbers) - Supplemental
Information

Dear Sir:

Pursuant to Section 50.59 of the Commission's Rules and Regulations, Vermont Yankee Nuclear Power Corporation hereby proposes the following change to Appendix A of the Operating License.

Proposed Change:

Replace Pages 116b, c, and e of Proposed Change No. 108, Reference (b), with the enclosed revised Pages 116b, c, and e. These pages have been revised to reflect the deletion of snubber RHR-H188 and to clarify snubber designations.

Reason For Change:

By Reference (b), we submitted Proposed Change No. 108 to our facility Technical Specifications. This change reflected the addition and deletion of safety-related shock suppressors (snubbers) resulting from modifications made in conjunction with our Mark I Containment Long-Term Program.

Page 116C has subsequently been revised to reflect the deletion of Snubber RHR-H188. This snubber is being removed coincident with our Mark I Program torus-attached piping modifications and will be replaced by a rigid restraint. In addition, two (2) sets of snubbers identified as single snubbers, or single units, on Pages 116b and e in our last submittal [Reference (b)], have been redesignated for clarity.

8308120188 830804
PDR ADUCK 05000271
P PDR

A001
111
Rec'd w/o check

