



Docket No. 50-346

License No. NPF-3

Serial No. 977

August 9, 1983

RICHARD P. CROUSE  
Vice President  
Nuclear  
(419) 259-5221

Director of Nuclear Reactor Regulation  
Attention: Mr. John F. Stolz  
Operating Reactor Branch No. 4  
Division of Operating Reactors  
United States Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Stolz:

This is in response to your letter dated July 15, 1983 (Log No. 1328), concerning Auxiliary Feedwater System Evaluation: NUREG-0737, Item II.E.1.1. In your letter you requested Toledo Edison to identify the specific cross-connect valves for the two condensate storage tanks which will be locked open. These valves are CD163 and CD164 as identified on Drawing No. M-006A for the Davis-Besse Nuclear Power Station Unit No. 1.

Very truly yours,

RPC:JBV:lah

cc: DB-1 NRC Resident Inspector

A046  
1/0