

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PHONE: (717) 542-2181 Ex3759

NRC USE ONLY



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

August 5, 1983

Dr. Thomas E. Murley  
Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 83-101/03L-0  
ER 100450 FILE 841-23  
PLA-1781

Docket No. 50-387  
License No. NPF-14

Dear Dr. Murley:

Attached is Licensee Event Report No. 83-101/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that both primary containment atmosphere gaseous radioactivity monitoring channels were out of service for a period of approximately two and one-half days. Actions required by Technical Specification 3.4.3.1 were instituted appropriately.

H.W. Keiser  
Superintendent of Plant-Susquehanna

LAK/pjg

cc: G.G. Rhoads  
Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 52  
Shickshinny, PA 18655

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

IE22  
11