



RICHARD P. CROUSE  
Vice President  
Nuclear  
(419) 259-5221

Docket No. 50-346  
License No. NPF-3  
Serial No. 984  
September 1, 1983

Director of Nuclear Reactor Regulation  
Attention: Mr. John F. Stolz  
Operating Reactor Branch No. 4  
Division of Operating Reactors  
United States Nuclear Regulatory Commission  
Washington, DC 20555

Dear Mr. Stolz:

Under separate cover, we are transmitting three (3) original and forty (40) conformed copies of an application for Amendment to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station Unit No. 1.

This application requests that the Davis-Besse Nuclear Power Station Unit 1 Technical Specifications, Appendix A, be revised to reflect the changes attached. The proposed changes involve Section 3.7.7, Table 3.7-3 and Bases.

The attachment identifies the proposed changes and its safety evaluation and significant hazard consideration. The requested change revises snubber surveillance requirements to include mechanical snubbers with schedules, actions and acceptance criteria for sample testing.

This amendment request involves a change of Class III type. Enclosed is a check for \$4,000 as requested by 10CFR170.22.

Very truly yours,

RPC:GAB

Attachment

cc: DB-1 NRC Resident Inspector  
James W. Harris

*Acc'd w/ check \$4,000*