



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

September 1, 1983

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station

Unit 1

Docket No. 50-416

License No. NPF-13

File 0260/L-835.0

Special Report 83-054/1 -

Update Report - Fire Rated

Doors Blocked Open to

Support Planned Maintenance

Activities

AECM-83/0531

This is an update to a previous report submitted on July 13, 1983. The conditions for which the report was submitted occurred beginning on June 8, 1983, when the following fire rated doors were blocked open to support planned maintenance activities in areas of the Auxiliary and Control Buildings:

- OC307 - Electrical chase, Control Building
- OC503 - Control Building, east entrance
- OC502 - East Stairway entrance, Control Building
- OC703 - Upper Cable Spreading Room, east entrance
- OC705 - Control Cabinet Room, east entrance
- 1A413 - Auxiliary Building, south stairway entrance
- 1A404 - Containment Ventilation Equipment Room

Fire watches were established in accordance with Technical Specification 3.7.7 as part of the planned activities. These conditions were reported pursuant to Technical Specification 6.9.2. All doors have been restored to operability and the last LCO associated with the planned maintenance activities was lifted on August 22, 1983. This is a final report.

Yours truly,

L. F. Dale

Manager of Nuclear Services

8309120371 830901  
PDR ADOCK 05000416  
S PDR

EBS/SHH:sap

cc: (See Next Page)

Member Middle South Utilities System

OFFICIAL COPY

1022

1/0

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0531

Page 2

cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555